

NOTES:

- 1. MANHOLE SEAL TO BE "WRAPIDSEAL" MANUFACTURED BY CCI PIPELINE SYSTEMS, "CRETEX WRAP" MANUFACTURED BY CRETEX SPECIALTY PRODUCT, "INFI-SHIELD GATOR WRAP" MANUFACTURED BY SEALING SYSTEMS, INC. OR APPROVED EQUAL.
- 2. MANHOLE JOINT SEAL INSTALLED AS DIRECTED BY AUTHORITY PERSONNEL, AND ON ALL JOINTS BELOW FINISHED GRADE.

HEAT SHRINKABLE MANHOLE SEAL

NOT TO SCALE



369 East Park Driv 367 East Fark Drive Harrisburg, PA 17111 (717) 564-1121 Fax (717) 564-1158 hrg@hrg-inc.com www.hrg-inc.com

COLUMBIA COUNTY

SCOTT	TOWNSHIP AUTHORITY
ST	TANDARD DETAILS

PENNSYLVANIA

PROJ. MGR JJM	DETAIL NO
DESIGN- WGR] D7
CADD- RSF	71 P'
CHECKED-	SHEET NO
SCALE- N.T.S.	1 OF
[DOG TOT 0057