



**NOTES:**

1. ALL CONCRETE SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 3000 P.S.I. AT THE END OF 28 DAYS.
2. ALL REINFORCING STEEL SHALL BE DEFORMED BARS.
3. NO COUPLINGS OR JOINTS SHALL BE COVERED WITH CONCRETE.

**THRUST BLOCKING**  
NOT TO SCALE

File name: P:\0057\005755\_0428\CAD\Standard Details\THRUST.dwg Layout: 1 Oct 12 2011 8:40am afrcbt



369 East Park Drive  
Harrisburg, PA 17111  
(717) 564-1121  
Fax (717) 564-1158  
hrg@hrg-inc.com  
www.hrg-inc.com

**SCOTT TOWNSHIP AUTHORITY  
STANDARD DETAILS**

COLUMBIA COUNTY

PENNSYLVANIA

PROJ. MGR. - JIM
DESIGN- WGR
CADD- RSF
CHECKED-
SCALE- N.T.S.
DATE- OCT. 2011

DETAIL NO.

**D25**

SHEET NO.

**1 OF 5**

PROJECT 005755.0428