

4 - 5/8"Ø S.S. BOLT HOLES
WITH 1/2"Ø COVER BOLTS


FRAME BOLT HOLE
1"Ø 4 REQUIRED
EQUALLY SPACED

PROVIDE DIAMOND
TOP SURFACE

CONCEALED WATERTIGHT
PICK HOLE.
2 EACH PER COVER

2" RAISED LETTER
FLUSH W/ TOP OF LID

SS LIFT RING 2X (TYP.)



PLAN

27 3/4"

25 3/4"

1/2"

7"-8"

PROVIDE NEOPRENE
GASKET OR "O" RING IN
MACHINED GROOVE IN LID

24"

36"

SECTION

WATERTIGHT MANHOLE

NOT TO SCALE

File name: P:\0057\005755_0428 (32) Standard Details\Jah-WATERTIGHT.dwg Layout: 1 Oct 12, 2011--7:48am efocht



369 East Park Drive
Harrisburg, PA 17111
(717) 564-1121
Fax (717) 564-1158
hrg@hrg-inc.com
www.hrg-inc.com

**SCOTT TOWNSHIP AUTHORITY
STANDARD DETAILS**

COLUMBIA COUNTY

PENNSYLVANIA

PROJ. MGR. - JJM
DESIGN-- WGR
CADD-- RSF
CHECKED--
SCALE-- N.T.S.
DATE-- OCT. 2011

DETAIL NO.

D12

SHEET NO.

1 OF 1

PROJECT 005755.0426